

DRINKING WATER AND SANITATION DIVISION GIRIDIH

DISTRICT LEVEL WATER TESTING LABORATORY

WATER TEST REPORT

DATE 06/03/2020

CUSTOMER NAME -

SOURCE OF THE SAMPLE - P/W

BLOCK - Giridih G.P. Pinda-tar VILLAGE Pariyans

TOLA - Rami Khawa

PHYSICAL LOCATION - Kendriya Vidyalaya Giridih

SAMPLE COLLECTED BY - School

S No.	TESTED PARAMETERS	UNIT	BIS DISIRABLE LIMIT	BIS PERMISSBLE LIMIT	ACTUAL LEVEL
1	IRON	Mg/l	0.3	1.0	0.3
2	FLUORIDE	Mg/l	1.0	1.5	1.0
3	CHLORIDE	Mg/l	250	1000	150
4	T.D.S	Mg/l	500	2000	100
5	ALKALIMITY	Mg/l	200	600	100
6	TURBIDITY	NTU	1.0	5.0	-
7	HARDNESS	Mg/l	300	600	110
8	ph		6.5	8.5	7.5
9	NITRATE	Mg/l	45	45	-

REMARKS - As per mentioned Parameters analyzed, Water Sample is accepted for drinking Purposes

M. Kumar
CHEMIST 06/03/20
District water testing
Laboratory, Giridih

Jai Bhagat
J.E 06/03/20
District water testing
Laboratory, Giridih

3/11 06/03/20
A.E
DW&SD, Giridih
Sub Division Office Giridih